



**NOTE : BOTTOM OF DUCT IS 3255mm ABOVE FINISHED FLOOR.**

**NOTE : FITTINGS A-1 THROUGH A-4 AND B-1 THROUGH B-3 HAVE BEEN DELETED AS PER CUSTOMERS REQUEST.**

**■ - DENOTES MOTORIZED DAMPER LOCATION**  
**■ - DENOTES FIRE DAMPER LOCATION**

**NOTE : FITTINGS A-23 AND B-28 ARE BEING SHIPPED BUT HAVE BEEN DELETED AND REPLACED WITH A-23-1, A-23-2, A-23-3, B-28-1, AND B-28-2.**

REV	DESCRIPTION	DATE	BY
0	AS BUILT DRAWING	12 JUN 25	CT
E	ISSUED FOR APPROVAL	12 APR 26	CT
D	ISSUED FOR APPROVAL	12 APR 11	CT
C	ISSUED FOR APPROVAL	12 APR 05	CT

**CROSSTOWN** Metal Industries Ltd.  
 No. 100, 13133 - 115 Avenue  
 Surrey, B.C., Canada, V3R 2V8  
 Tel. 604-589-3133  
 Fax. 604-589-3134

CLIENT REF: [ ]  
 MAC REF: [ ]  
 DRAWN: C.THIESSEN 12 MAR 09  
 DESIGN: [ ]  
 SCALE: 1/50 Y/M/D

**MOA CUBA**  
**LEVEL 2.50 - AHU 101**  
**RETURN AND SUPPLY AIR**

CAD FILE NO. D 7660 100 0  
 SIZE PROJECT NO. DRAWING NO. REV.

COPYRIGHT OF THIS DRAWING, THE DESIGN CONTAINED HEREIN, AND ALL ASSOCIATED DOCUMENTS ARE RESERVED BY THE DESIGNER. THE CONTENTS MAY NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT PRIOR WRITTEN CONSENT OF THE DESIGNER.